

IEC

IECEE



Ref. Certif. No.

CN61230

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Molded case circuit breakers

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NM8N-800;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th
Edition)As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2023CQC-106735

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Aug.29,2023

Signature:

谢肇煦

Xie ZhaoXu



NM8N-800

Uimp: 12kV;

Ui: 1000V;

Ue: AC380/400/415V, AC440V, AC500V, AC660/690V;

In: 500A (Thermo-magnetic only), 630A, 700A, 800A;

Over-current release: Thermo-magnetic, Electronic;

Ics: AC380/400/415V: 36/50/70/100/150kA (C/S/Q/H/R);

AC440V: 36/50/70/100/100kA (C/S/Q/H/R);

AC500V: 25/40/40/50/100kA (C/S/Q/H/R);

AC660/690V: 12/15/15/15/15kA (C/S/Q/H/R);

Icu: AC380/400/415V: 36/50/70/100/150kA (C/S/Q/H/R);

AC440V: 36/50/70/100/100kA (C/S/Q/H/R);

AC500V: 25/40/40/50/100kA (C/S/Q/H/R);

AC660/690V: 12/15/15/20/30kA (C/S/Q/H/R);

Icw: 10kA/1s;

Trip grade: 5, 10, 20, 30 (Electronic ENM, EMM);

Selectivity category: A (Thermo-magnetic), B (Electronic);

Poles: 3P, 3P+N (3 protected poles with an uninterrupted neutral pole), 4P (3 protected poles with a switched neutral pole), 4P;

Suitable for isolation;

Rated frequency: 50/60Hz;

IP20


Page 1 of 1

Additional information (if necessary)

Date:

Aug.29,2023

Signature:


Xie ZhaoXu